




BULLOCK MFG Pty Ltd.


Model 9900/M

Intumescent Module Fire Damper




Product Description

Bullock Model 9900 Intumescent Module Fire Dampers are designed to impede the spread of fire and combustible materials to other compartments through the air handling systems. The evenly spaced intumescent strips expand on heat to form a solid barrier against flame, smoke and hot gases. Complying with AS1682.1-1990 and AS/NZS 1668.1-1998, the Model 9900 module is tested and certified for a 4 hour fire rating (FRL) in ductwork passing through a masonry wall to AS1530.4.



Product Features

- CSIRO tested and certified for a 4 hour FRL - Certificate of test number - 1277.
- Test number FS3437 / 2189 - in ductwork mounted design.
- Sponsored investigation number - FSP 0869.
- Complies with AS/NZS 1668.1 - 1998 with a tested closure rate of 65 seconds.
- No fire damper body or flanges are required.
- Lightweight construction without welding ensures the integrity of the dampers' galvanised coating.
- No extra mounting angles required to securely fix damper within ductwork, within masonry wall.
- Each Intumescent strip is sheathed in aluminium foil for ease of maintenance to AS1851.6.
- Sizes range from 100mm x 100mm up to 300mm x 300mm and are available at short notice.



Installation

Compliance with installation instructions is critical. Refer to separate wall/slab type installation instructions to suit your requirements. Please refer to installation Page.

Maintenance

This model requires little maintenance once installed. Refer to AS1851.6-1997 for detailed servicing procedures.

Specifications are subject to change without notice.

BULLOCK MFG P/L ~ 22 Pike St. Rydalmere. NSW 2116 Ph:(02)9684 1311 Fax:(02)9684 2250

BULLOCK VIC P/L ~ 54 Tarnard Dr. Braeside. VIC 3195 Ph:(03)9587 5522 Fax:(03)9587 6622

BULLOCK WA P/L ~ 34 Industry St. Malaga. WA 6062 Ph:(08)9248 1633 Fax:(08)9248 1733

BULLOCK INDUSTRIES P/L ~ 26 Quindus St, Wacol. QLD 4076 Ph:(07) 3271 2088 Fax:(07)3271 1892

BULLOCK SA P/L ~ U1 Commercial Crt. Dry Creek. SA 5094 Ph:(08) 8349 7088 Fax:(08)8349 7066

email:bullmfg@bigpond.net.au

Copyright © 2004 Bullock Manufacturing Pty Limited. All Rights Reserved.