



# BULLOCK


# MODEL 5650

## Masonry Wall without Metal Expansion Gap Seals

## 4 Hour Rating

### INSTALLATION INSTRUCTIONS

1. **INITIAL DAMPER TEST** Before installing damper into wall, check damper's closing operation. This can be achieved by removing UI33 fusible link. Hold the damper in a stable upright position, then using the link strap or the "cricket bat" push the blade vertically to the top. This will clear the blade over the two locking tabs. Pivot the blade back against the stainless steel spring(s) to the full open position then let the blade close and lock. Replace fusible link and close link strap.
2. Remove flange screws and detach flanges from damper casing. Ensure wall penetration is correct size. Opening should be as to AS1682.2-1990 Clause C.
3. Wrap damper with suitable high temperature insulation and slide into wall penetration.  
**NOTE:** All dampers are clearly labelled with "TOP" and "AIRFLOW DIRECTION" orientation labels these must be adhered to.
4. Replace flanges making sure damper is firmly fixed within the wall.  
**NOTE:** Do not overtighten flange screws.
5. Now that the damper is securely fixed and sealed within the slab repeat **POINT #1. INITIAL DAMPER TEST**.
6. Connect ductwork to fire damper using fire resistant mastic to fill recess if using raw edge connection or apply mastic to both surfaces of the TDF/TDC flange connections. (Bolts must be a low melting point material.)



### MAINTENANCE INSTRUCTIONS

All Fire Dampers shall be accessible and maintained in accordance with AS 1851.6.

Bullock Mfg P/L	22 Pike Street, Rydalmerle 2116	P:9684 1311 F:9684 2250	sales@bullockmfg.com.au
Bullock Industries P/L	26 Quindus Street, Wacol 4076	P:3271 2088 F:3271 1892	reception@bullockqld.com.au
Bullock SA P/L	1 Commercial Court, Dry Creek 5094	P:8349 7088 F:8349 7066	scott@bullocks.com.au
Bullock Vic P/L	54 Tarnard Drive, Braeside 3195	P:9587 5522 F:9587 6622	admin@bullockvic.net.au
Bullock WA P/L	34 Industry Street, Malaga 6062	P:9248 1633 F:9248 1733	reception@bullockwa.com.au